



Town of Halifax
Board of Health
Supplementary Rules and Regulations to the
State Environmental Code: Title V,
310 CMR 15.00

Adopted: November 12, 2004.

Revised: December 01, 2004.

Revised: August 19, 2015.

Revised: December 09, 2020.

Amended: December 09, 2020. **Effective:** January 01, 2021.

Revised: February 17, 2021.



TOWN OF HALIFAX

COMMONWEALTH OF MASSACHUSETTS

Board of Health

499 Plymouth St., Halifax, MA 02338
*Telephone (781) 293 6768 *Fax (781) 293 1738

Supplementary Rules and Regulations to the State Environmental Code: Title 5, 310 CMR 15,000

“Standard Requirements for the siting, construction, inspection, upgrade and expansion of on-site sewage treatment and disposal systems.”

1.07 Septic Installations

- (1) An approved copy of the proposed plan and the disposal works permit will always be on-site during construction.
- (2) There will be a 24-hour water test for tight tanks.
- (3) The following inspections, at a minimum, shall be conducted by the Health Agent or Board approved consultant during the installation of the system.
 - a. Bottom Hole Inspection.
 - b. Final Inspection.
- (4) If at the time of any inspection, the system does not comply with the design plans, there will be an additional charge for every re-inspection.
- (5) Pump Chambers will have risers with cover at grade above the pump. Duplex Pump Chambers will have a hatch that will provide access to both pumps. The cover shall have a gasket and the unit will be vented.
- (6) Cast Iron/Plastic Covers.
 - a. All covers shall be at grade and tamper resistant at inlet and outlet.
 - b. All components (pump/filter, etc....) shall be serviceable components.